



Idaho Department of Environmental Quality Draft §401 Water Quality Certification

April 17, 2012

NPDES Permit Number(s): ID-002285-3 City of Coeur d'Alene Wastewater Facility

Receiving Water Body: Spokane River

Pursuant to the provisions of Section 401(a)(1) of the Federal Water Pollution Control Act (Clean Water Act), as amended; 33 U.S.C. Section 1341(a)(1); and Idaho Code §§ 39-101 et seq. and 39-3601 et seq., the Idaho Department of Environmental Quality (DEQ) has authority to review National Pollutant Discharge Elimination System (NPDES) permits and issue water quality certification decisions.

Based upon its review of the above-referenced permit and associated fact sheet, DEQ certifies that if the permittee complies with the terms and conditions imposed by the permit along with the conditions set forth in this water quality certification, then there is reasonable assurance the discharge will comply with the applicable requirements of Sections 301, 302, 303, 306, and 307 of the Clean Water Act, the Idaho Water Quality Standards (WQS) (IDAPA 58.01.02), and other appropriate water quality requirements of state law.

This certification does not constitute authorization of the permitted activities by any other state or federal agency or private person or entity. This certification does not excuse the permit holder from the obligation to obtain any other necessary approvals, authorizations, or permits.

Antidegradation Review

In March 2011, Idaho incorporated new provisions in Idaho Code § 39-3603 addressing antidegradation implementation. At the same time, Idaho adopted antidegradation implementation procedures in the Idaho WQS. DEQ submitted the antidegradation implementation procedures to the US Environmental Protection Agency (EPA) for approval on April 15, 2011. On August 18, 2011, EPA approved the implementation procedures.

The WQS contain an antidegradation policy providing three levels of protection to water bodies in Idaho (IDAPA 58.01.02.051).

- **Tier 1 Protection.** The first level of protection applies to all water bodies subject to Clean Water Act jurisdiction and ensures that existing uses of a water body and the level of water quality necessary to protect those existing uses will be maintained and protected (IDAPA 58.01.02.051.01; 58.01.02.052.01). Additionally, a Tier 1 review is performed for all new or reissued permits or licenses (IDAPA 58.01.02.052.05).
- **Tier 2 Protection.** The second level of protection applies to those water bodies considered high quality and ensures that no lowering of water quality will be allowed unless deemed

necessary to accommodate important economic or social development (IDAPA 58.01.02.051.02; 58.01.02.052.06).

- Tier 3 Protection. The third level of protection applies to water bodies that have been designated outstanding resource waters and requires that activities not cause a lowering of water quality (IDAPA 58.01.02.051.03; 58.01.02.052.07).

DEQ is employing a water body by water body approach to implementing Idaho's antidegradation policy. This approach means that any water body fully supporting its beneficial uses will be considered high quality (Idaho Code § 39-3603(2)(b)(i)). Any water body not fully supporting its beneficial uses will be provided Tier 1 protection for that use, unless specific circumstances warranting Tier 2 protection are met (Idaho Code § 39-3603(2)(b)(iii)). The most recent federally approved Integrated Report and supporting data are used to determine support status and the tier of protection (Idaho Code § 39-3603(2)(b)).

Pollutants of Concern

The City of Coeur d'Alene discharges the following pollutants of concern: carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), pH, E. coli, chlorine, ammonia, phosphorus, silver, lead, cadmium and zinc. Effluent limits have been developed for all pollutants of concern.

Receiving Water Body Level of Protection

The City of Coeur d'Alene discharges to the Spokane River assessment unit (AU) ID17010305PN004_04. This AU has the following designated beneficial uses: cold water aquatic life, salmonid spawning, primary contact recreation, domestic, agricultural and industrial water supply, wildlife habitat, and aesthetics. There is no available information indicating the presence of any existing beneficial aside from those that are already designated.

The cold water aquatic life use in the Spokane River AU is not fully supported due to excess cadmium, lead, zinc and phosphorus (2010 Integrated Report). The primary contact recreation beneficial use is fully supported. As such, DEQ will provide Tier 1 protection only for the aquatic life use and Tier 2 protection, in addition to Tier 1, for the recreation beneficial use (Idaho Code § 39-3603(2)(b)).

Protection and Maintenance of Existing Uses (Tier 1 Protection)

As noted above, a Tier 1 review is performed for all new or reissued permits or licenses, applies to all waters subject to the jurisdiction of the Clean Water Act, and requires demonstration that existing uses and the level of water quality necessary to protect existing uses shall be maintained and protected. In order to protect and maintain designated and existing beneficial uses, a permitted discharge must comply with narrative and numeric criteria of the Idaho WQS, as well as other provisions of the WQS such as Section 055, which addresses water quality limited waters. The numeric and narrative criteria in the WQS are set at levels that ensure protection of designated beneficial uses. The effluent limitations and associated requirements contained in the City of Coeur d'Alene permit are set at levels that ensure compliance with the narrative and numeric criteria in the WQS.

Water bodies not supporting existing or designated beneficial uses must be identified as water quality limited, and a total maximum daily load (TMDL) must be prepared for those pollutants causing impairment. A central purpose of TMDLs is to establish wasteload allocations for point source discharges, which are set at levels designed to help restore the water body to a condition that supports existing and designated beneficial uses. Discharge permits must contain limitations that are consistent with wasteload allocations in the approved TMDL.

The WQS provide that until a TMDL or equivalent process is completed for a high priority water quality limited waterbody, the total load of the impairing pollutant must remain constant or decrease within the watershed. (IDAPA58.01.02.055.04). The cold water aquatic life use in the Spokane River AU is not fully supported due to excess cadmium, lead, zinc and phosphorus (2010 Integrated Report). In addition, the 2010 Integrated Report lists the Spokane River as high priority for TMDL development. Therefore, section 055.04 is applicable to the discharges of phosphorus, lead, zinc and cadmium.

Phosphorus

The restrictions on loading set forth in 055.04 are only applicable until a TMDL or equivalent process is completed. DEQ believes a process equivalent to a TMDL has been completed for phosphorus. In order to meet Washington and Idaho WQS, EPA modeled the cumulative impact of all sources of nutrients and oxygen-demanding pollutants, both point and non-point sources, in Idaho and Washington. The limits EPA has set in the draft permits for the point sources in Idaho, including the CDA permit, are based upon this loading analysis. The proposed effluent limits will result in a concentration of approximately 9.1µg/L in the Idaho portion of the Spokane River. This level meets or exceeds Idaho's narrative criteria for excess nutrients. (See IDAPA 58.01.02.200.06). In sum, equivalent to a TMDL, EPA has calculated the loading from point and non-point sources, and set limits that will attain WQS for phosphorus in Idaho. Therefore, the effluent limits in the draft permit are consistent with section 055.04.

Even assuming the restrictions on loading set forth in section 055.04 are applicable, the phosphorus limits in the draft permit comply with the restrictions. The interim limits retain the current phosphorus loading, and the final limits will require reductions in the level of phosphorus discharged.

Cadmium, Zinc and Lead

In August 2000, EPA approved a TMDL prepared by DEQ for cadmium, lead and zinc in the CDA River Basin, which included the Spokane River. The TMDL included allocations for the point source dischargers to the Spokane River, including CDA. However, this TMDL was invalidated by the Idaho Supreme Court in 2003. There has been no more recent effort by DEQ to develop a TMDL for metals in the Spokane River, and therefore, the river is still on the state's 303d list for metals and is identified as a high priority water body for TMDL development. Thus, the load restrictions in section 055.04 apply to the metals discharged to the Spokane River.

The intent of section 055.04 is to ensure that water quality is at least maintained at current levels, until DEQ can make a determination, through a TMDL or equivalent process, regarding reductions necessary to attain WQS. To achieve this goal, section 055.04 requires that the "load" of the impairing pollutant remain constant or decrease in the watershed. "Load" is not defined in the Idaho WQS. The term is defined, however, in the federal regulations that address TMDL

development. Since section 055.04 is part of the WQS that address TMDL development it is appropriate to look to the federal TMDL regulations for guidance. 40 CFR 130.2(e) defines load or loading as follows: “An amount of matter or thermal energy that is introduced into a receiving water; to introduce matter or thermal energy into a receiving water. Loading may be either man-caused (pollutant loading) or natural (natural background loading).” In the context of a NPDES permit, an amount of matter is identified by a mass-based limit. Therefore, the mass-based limits for the applicable metals in the reissued Spokane River NPDES permits must be kept constant in order to comply with section 055.04.

In the draft NPDES permit for CDA, EPA has set limits for zinc that maintain the currently permitted design flow load of this pollutant to meet provisions of section 055.04 of the WQS (See Table 1 footnote 4). However, the draft permit does not contain cadmium or lead limits. In order to ensure compliance with section 055.04, DEQ has included in the draft certification cadmium and lead limits that reflect CDA’s current cadmium and lead loading. The City of Coeur d’Alene is not requesting a design flow increase.

Section 055.04 provides that once a TMDL or equivalent process is completed, the discharge of causative pollutants must be consistent with the TMDL or equivalent process. Therefore, once a TMDL for metals is completed by DEQ and approved by EPA, the limits for metals in the permit, including the loading limits discussed herein, should be adjusted to reflect the approved TMDL.

In summary, the effluent limitations and associated requirements contained in the CDA permit are set at levels that ensure compliance with the narrative and numeric criteria in the WQS. Therefore, DEQ has determined the permit will protect and maintain existing and designated beneficial uses in the Spokane River.

Table 1. Comparison of current and proposed permit limits.

		Proposed Permit			Current Permit			Change ¹
Parameter	Units	Average Monthly Limit	Average Weekly Limit	Maximum Daily	Average Monthly Limit	Average Weekly Limit	Maximum Daily	
Pollutants with limits in both the current and proposed permit								
CBOD ₅ November-January	mg/L	25	40	-	30	45	-	I ²
	lb/day	1251	2002	-	871	1306	-	
	% removal	85%	-	-	85%	-	-	
CBOD ₅ February-March	mg/L	25	40	-	30	45	-	D
	lb/day	295	472	-	871	1306	-	
	% removal	85%	-	-	85%	-	-	
CBOD ₅ April-October	mg/L	25	40	-				D
	lb/day	265	424	-				D
	% removal	85%	-	-				D
TSS	mg/L	30	45	-	30	45	-	I ²
	lb/day	1501	2252	-	1,500	2,250	-	
	% removal	85%	-	-	85%	-	-	
pH October-June	s.u.	6.3 – 9.0 all times			6.2 – 9.0 all times			D
pH July-September	s.u.	6.5 – 9.0 all times			6.3 – 9.0 all times			D
E. coli	#/100 mL	126	-	406	-	-	-	nc ³
Fecal coliform ³ May-Sept	#/100 mL	-	-	-	50	200	500	nc ³
Fecal coliform ³ October-April	#/100 mL	-	-	-	-	200	800	nc ³
Total Residual Chlorine October-June	µg/L	150	-	390	36	-	161	I ²
	lb/day	7.5	-	20	1.04	-	4.67	
Total Residual Chlorine July-Sept	µg/L	39	-	102	147	-	662	I ²
	lb/day	2.0	-	5.1	4.27	-	19.2	
Ammonia (July-Sept)	mg/L	-	-	-	10	-	29	D
	lb/day		≤4mgd	-	350		1,000	D
Ammonia (July-Sept)	mg/L	-		-	7.4	-	21	D
	lb/day	-	>4.2mgd		370	-	1,100	D
Ammonia July-Sept interim limits	mg/L	10	-	29				nc
	lb/day	350	≤4mgd	1,000		-		nc
Ammonia July-Sept interim limits	mg/L	7.4	-	21				nc
	lb/day	370	>4.2mgd	1,100				nc
Ammonia (March-June)	mg/L	-	-	-	-	-	-	-
	lb/day	649	-	1547	-	-	-	D
Ammonia (July-Sept)	mg/L	6.59	-	15.7	-	-	-	D
	lb/day	330	-	786	-	-	-	D
Ammonia (October)	mg/L	-	-	-	-	-	-	-
	lb/day	525	-	1252	-	-	-	nc
Ammonia (March-Oct)	mg/L	-	-	-	-	-	-	-
	lb/day	Seasonal Average Limit 272lb/day			-	-	-	D

Table 1 Continued...

Table 1 Continued...

		Proposed Permit			Current Permit		Change ¹	
Parameter	Units	Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit	Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit	
Pollutants with limits in both the current and proposed permit (continued)								
Phosphorus (March-Oct)	percent removal	-	-	-	85%	-	-	D
phosphorus Feb-Oct ⁵ interim limits	µg/L	1,000	1,600	-				nc
	lb/day	50	80					nc ⁵
Phosphorus February-October	µg/L	-	-	-	-	-	-	D
	lb/day	3.17 seasonal	average	-	-	-	-	D
Silver (Oct-June>4.2 mgd	µg/L	8.01	-	22.5	16.0	-	31.9	D
	lb/day	0.401	-	1.13	0.80	-	1.60	D
Zinc	µg/L	135	-	168	136.2	-	200.8	D
	lb/day	6.76	-	8.42	6.8	-	10.0	D
Pollutants with limits only in the proposed permit								
Cadmium ⁴	µg/L	0.64	-	1.11	-	-	-	nc ⁴
	lb/day	0.032	-	0.056	-	-	-	nc ⁴
Lead ⁴	µg/L	3.60	-	7.73	-	-	-	nc ⁴
	lb/day	0.1801	-	0.387	-	-	-	nc ⁴

Table 1 Continued...

		<i>Proposed Permit</i>			<i>Current Permit</i>			<i>Change¹</i>
<i>Parameter</i>	<i>Units</i>	<i>Average Monthly Limit</i>	<i>Average Weekly Limit</i>	<i>Maximum Daily Limit</i>	<i>Average Monthly Limit</i>	<i>Average Weekly Limit</i>	<i>Maximum Daily Limit</i>	
<i>Pollutants with no limits in either the current and proposed permit</i>								
<i>Temperature</i>	<i>°C</i>	<i>Report</i>	-	<i>Report</i>	-	-	<i>Report</i>	<i>nc</i>
<i>PCB</i>	<i>pg/L</i>	<i>Report</i>		<i>Report</i>	-	-	-	<i>nc</i>
<i>Mercury</i>	<i>ng/L</i>	-	-	-	-	-	-	<i>nc</i>
<i>TCDD</i>	<i>pg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Silver</i>	<i>µg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
	<i>lb/day</i>	-	-	-	-	-	-	
<i>Alkalinity</i>	<i>mg/L as CaCO₃</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Hardness</i>	<i>mg/L as CaCO₃</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Oil and Grease</i>	<i>mg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>TDS</i>	<i>mg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Ortho-phosphate</i>	<i>µg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Kjeldahl Nitrogen</i>	<i>mg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Nitrate-Nitrite</i>	<i>mg/L</i>	<i>Report</i>	-	<i>Report</i>	-	-	-	<i>nc</i>
<i>Dissolved Oxygen</i>	<i>mg/L</i>	<i>Report minimum and average</i>			-	-	-	<i>nc</i>

¹ *nc* = no change in effluent limit from current permit; *I* = increase of pollutants from current permit; *D* = decrease of pollutants from current permit;

² These pollutants are significant to the cold water aquatic life use which is impaired and therefore, receives only Tier 1 protection. The increased loads of these pollutants in the draft permit do not exceed narrative or numeric criteria in the Idaho WQS which meets the requirements for Tier 1 protection.

³ DEQ requested EPA replace the fecal coliform limits with *E. coli* effluent limits. These limits are considered equivalent. See discussion under High Quality Waters section (below).

⁴ Effluent limits for cadmium and lead have been added by the 401 certification to ensure that the load of these metals remain constant in the watershed to meet the requirements of IDAPA 58.01.02.055.04. To be consistent, these limits were developed using the 2006-2011 DMR data and based on the method used by EPA in 1999 for the development of zinc limits in the current permit.

⁵ Interim effluent limits for phosphorus were established based on Coeur d'Alene's current design flow and treatment levels authorized by their current permit. See discussion on page 3 regarding the use of an equivalent process.

High-Quality Waters (Tier 2 Protection)

The Spokane River is not assessed for recreation use. Monitoring data for *E. coli* collected in 2007 within the subject assessment unit, indicates that the Spokane River is high quality for the primary contact recreation beneficial use. As such, the water quality relevant to recreational uses of the Spokane River must be maintained and protected, unless a lowering of water quality is deemed necessary to accommodate important social or economic development.

To determine whether degradation will occur, DEQ must evaluate how the permit issuance will affect water quality for each pollutant that is relevant to recreational uses of the Spokane River (IDAPA 58.01.02.052.04). These include the following: *E. coli* bacteria, phosphorus and mercury. Effluent limits are set in the proposed and existing permit for all these pollutants except mercury.

For a reissued permit or license, the effect on water quality is determined by looking at the difference in water quality that would result from the activity or discharge as authorized in the current permit and the water quality that would result from the activity or discharge as proposed in the reissued permit or license (IDAPA 58.01.02.052.04.a). For a new permit or license, the effect on water quality is determined by reviewing the difference between the existing receiving water quality and the water quality that would result from the activity or discharge as proposed in the new permit or license (IDAPA 58.01.02.052.04.a).

Pollutants with Limits in the Current and Proposed Permit: *E. coli*, phosphorus

For Tier 2 related pollutants that are currently limited (have effluent limits) and will have limits under the reissued permit, the current discharge quality is based on the limits in the current permit or license (IDAPA 58.01.02.052.04.a.i), and the future discharge quality is based on the proposed permit limits (IDAPA 58.01.02.052.04.a.ii). For the City of Coeur d'Alene permit, this means determining the permit's effect on water quality based upon the limits for *E. coli* and phosphorus in the current and proposed permits. Table 1 provides a summary of the current permit limits and the proposed or reissued permit limits.

E. coli

The existing permit for the City of Coeur d'Alene contains effluent limits for fecal coliform and *E. coli*. In 1986, EPA updated its criteria to protect recreational use of water by recommending an *E. coli* criterion as a better indicator than fecal coliform of bacteria levels that may cause gastrointestinal distress in swimmers. In 2000, DEQ changed its bacteria criterion from fecal coliform to *E. coli*. The *E. coli* limits are in the existing permit to reflect the bacteria criterion that DEQ adopted to protect the contact recreation beneficial use (IDAPA 58.01.02.251.01). The fecal coliform limits are in the current permit because at the time the permit was issued, IDAPA 58.01.02.420.05 established a disinfection requirement for sewage wastewater treatment plant effluent. This requirement specified that fecal coliform concentrations not exceed a geometric mean of 200/100 mL based on a minimum of five samples in one week. This section of the Idaho WQS was revised in 2002 to reflect the change in the bacteria criterion from fecal coliform to *E. coli*. The *E. coli* limits are as or more protective of water quality than the old fecal coliform

limits. The proposed final permit contains both fecal coliform and *E. coli* effluent limits that comply with previous and current numeric “end-of-pipe” criteria.

Because the fecal coliform criterion has been replaced with an *E. coli* criterion, DEQ is requesting that EPA remove the fecal coliform effluent limits, consistent with how EPA has handled other NPDES permits for wastewater treatment plants in Idaho. Retaining the *E. coli* limits will ensure that the receiving water quality will not be degraded even when the fecal coliform limits are removed. Even with the omission of fecal coliform limits, DEQ believes the discharge will not cause or contribute to a violation of the bacteria criteria because the permit incorporates “end-of-pipe” limits for *E. coli*. Thus, removal of the fecal coliform limits complies with both the Tier 1 and Tier 2 components of Idaho’s antidegradation policy. Therefore, no adverse change in water quality and no degradation will result from the discharge of this pollutant.

Phosphorus

The proposed permit for Coeur d’Alene includes a new final effluent limit for phosphorus (draft permit Table 1). Tier 2 waters are waters in which the quality of the water is better than necessary to support beneficial uses. The tier 2 antidegradation policy provides that pollutants relevant to recreational uses may be significantly increased only if socially or economically justified. However, while the Spokane River is tier 2 for recreational uses, it is also impaired for aquatic life uses due to excess total phosphorous (TP). Because TP is relevant to both uses, and the water quality standards require both uses be protected, the use with the more stringent requirement limits the TP levels. Thus, the phosphorus levels must be reduced to get the River back into compliance with criteria for support of aquatic life uses. This needed reduction is reflected in the proposed permit limits. Because the River is impaired for phosphorus in Idaho, and because the CDA permit must ensure compliance with Washington WQS, the limits in the permit require a significant reduction in phosphorus. Specifically, the draft permit final effluent limits for the three Idaho dischargers will reduce phosphorus concentrations in the Idaho portion of the Spokane River to approximately 9.1µg/L at the state line. These limits meet the Tier 2 requirement under the antidegradation policy because there will be no degradation in water quality, but rather an improvement in TP levels.

Therefore, phosphorus limits in the proposed permit reflect a maintenance or improvement in water quality from current conditions and no adverse change in water quality and no degradation will occur with respect to this pollutant.

Pollutants with No Limits

Mercury is a pollutant relevant to Tier 2 protection of recreation that currently is not limited and for which the proposed permit also contains no limit (Table 1). For such pollutants, a change in water quality is determined by reviewing whether changes in production, treatment, or operation that will increase the discharge of these pollutants are likely (IDAPA 58.01.02.052.04.a.ii). With respect to mercury, there is no reason to believe this pollutant will be discharged in quantities greater than those discharged under the current permit. This conclusion is based upon the fact that there have been no changes in the design flow, influent quality or treatment processes that would likely result in an increased discharge of this pollutant. Additionally, whole effluent toxicity testing using three different organisms will be required twice per year to detect toxics in toxic amounts. A toxicity reduction evaluation is required in the event of an excursion above a

trigger value. Mercury monitoring will be required three times over a five year period as part of the expanded effluent testing requirements in Part D of the NPDES application Form 2A (EPA Form 3510-2A, revised 1-99). Because of these provisions, the proposed permit does not allow for any increased water quality impact from this pollutant, DEQ concludes that the proposed permit should not cause a lowering of water quality for mercury. As such, the proposed permit should maintain the existing high water quality in the Spokane River.

Conditions Necessary to Ensure Compliance with Water Quality Standards or Other Appropriate Water Quality Requirements of State Law

The 2010 Integrated Report lists the Spokane River as high priority for TMDL development. Pursuant to IDAPA 58.01.02.055.04, DEQ must ensure that discharges of pollutants of concern remain constant or decrease within the watershed. Pollutants of concerns for which a TMDL is to be developed are cadmium, lead, zinc and total phosphorus. The draft permit lacks effluent limits for cadmium and lead because the discharge didn't have reasonable potential to exceed WQS criteria. Therefore, to meet Section 055.04 requirements, this 401 certification adds effluent limits as specified in Table 2, below.

Table 2: Final Effluent Limit Requirements for Outfall 001			
Parameter	Units	Average Monthly Limit	Maximum Daily Limit
*Lead	µg/L	3.60	7.73
	lbs/day	0.1801	0.387
*Cadmium	µg/L	0.64	1.11
	lbs/day	0.032	0.056

*Effluent limits for cadmium and lead were developed using 2006-2011 DMR data and based on the method used by EPA in 1999 for development of zinc effluent limits in the current permit. By setting an effluent limit for cadmium and lead that maintains the current load, this discharge complies with WQS Section 055.04.

Compliance Schedule

Pursuant to IDAPA 58.01.02.400.03, DEQ may authorize compliance schedules for water quality based effluent limits issued in a permit for the first time. City of Coeur d'Alene cannot immediately achieve compliance with the effluent limits for ammonia and phosphorus; therefore, DEQ authorizes a compliance schedule and interim requirements as set forth below. This compliance schedule provides the permittee a reasonable amount of time to achieve the final effluent limitations as specified in the permit. At the same time, the schedule ensures that compliance with the final effluent limits is accomplished as soon as possible.

1. The permittee must comply with all effluent limitations and monitoring requirements in Part I.B beginning on the effective date of the permit, except those for which a compliance schedule is specified in Part I.C.2.
2. A schedule of compliance is authorized for the following effluent limitations during seasons specified below:
 - a) Total phosphorus effluent limits in effect during February-October timeframe.
 - b) Total ammonia as N average monthly and maximum daily effluent limits in effect during March through September.
 - c) Seasonal average effluent limit for total ammonia as N in effect during March through October.
3. The permittee must achieve compliance with the final effluent limitations for total phosphorus and total ammonia as N as set forth in Part I.B. (Table 1) of the permit, not later than ten (10) years after the effective date of the final permit.
4. While the schedules of compliance specified in Part I.C.2 are in effect, the permittee must complete interim requirements and meet interim effluent limits and monitoring requirements as specified in Part I.D. of the permit.
5. All other provisions of the permit, except the final effluent limits for total phosphorus and total ammonia as N as described in paragraph 2 of this certification, must be met after the effective date of the final permit.

Interim Requirements for Compliance Schedules

1. By one (1) year after the effective date of the final permit, the permittee must provide a preliminary engineering report to EPA and IDEQ outlining estimated costs and schedules for completing capacity expansion and implementation of technologies to achieve final effluent limitations. This schedule must include a timeline for full scale pilot testing and results of any testing conducted to date.
2. By three (3) years after the effective date of the final permit, the permittee must provide written notice to EPA and IDEQ that full scale pilot testing of the technology that will be employed to achieve the final limits has been completed and must submit a summary report of results and plan for implementation.
3. By five years after the effective date of the final permit, the permittee must provide EPA and IDEQ with written notice that design has been completed and bids have been awarded to begin construction to achieve final effluent limitations.
4. By eight (8) years after the effective date of the final permit, the permittee must provide EPA and DEQ with written notice that construction has been completed on the facilities to achieve final effluent limitations.

5. By ten (10) years after the effective date of the final permit, the permittee must provide EPA and DEQ with a written report providing details of a completed start up and optimization phase of the new treatment system and must achieve compliance with the final effluent limitations of Part I.B. The report shall include two years of effluent data demonstrating that final effluent limits can be achieved by year ten (10).
6. By year six (6), seven (7), and eight (8) after the effective date of the final permit, the permittee must submit to EPA and IDEQ progress reports, which outline the progress made toward achieving compliance with the total phosphorus and total ammonia as N effluent limitations. At a minimum, the reports must include:
 - a) An assessment of the previous year of effluent data and comparison to the interim effluent limitations.
 - b) A report on progress made toward meeting the final effluent limits.
 - c) Further actions and milestones targeted for the upcoming year.
7. When the schedules of compliance specified in Part I.C.2 are in effect, the permittee must comply with interim effluent limitations and monitoring requirements as specified in Part I.D. of the permit.

Mixing Zones

Pursuant to IDAPA 58.01.02.060, DEQ authorizes a mixing zone that utilizes 25% of the 1Q10 critical flow volumes of the Spokane River for ammonia (March-October monthly average and maximum daily effluent limits), silver (October-June when effluent flow is >4.2mgd) and pH (October-June). Refer to Table 1 in the draft permit Fact Sheet for the 1Q10 flows and utilize the FERC license flow of 500cfs for the June-September timeframe.

Pollutant Trading

Pursuant to IDAPA 58.01.02.055.06, DEQ authorizes pollutant trading for phosphorus. Trading must be conducted in a manner that is consistent with the most recent version of DEQ's *Water Quality Pollutant Trading Guidance*, available at: http://www.deq.idaho.gov/media/488798-water_quality_pollutant_trading_guidance_0710.pdf. The use of pollutant offsets is authorized for purposes of compliance with antidegradation rules and IDAPA 58.01.02.055.

Other Conditions

This certification is conditioned upon the requirement that any material modification of the permit or the permitted activities—including without limitation, any modifications of the permit to reflect new or modified TMDLs, wasteload allocations, site-specific criteria, variances, or other new information—shall first be provided to DEQ for review to determine compliance with Idaho WQS and to provide additional certification pursuant to Section 401.

Right to Appeal Final Certification

The final Section 401 Water Quality Certification may be appealed by submitting a petition to initiate a contested case, pursuant to Idaho Code § 39-107(5) and the “Rules of Administrative Procedure before the Board of Environmental Quality” (IDAPA 58.01.23), within 35 days of the date of the final certification.

Questions regarding the actions taken in this certification should be directed to June Bergquist, Coeur d’Alene Regional Office at 208.666.4605 or via email at june.bergquist@deq.idaho.gov .

DRAFT

Daniel Redline
Regional Administrator
Coeur d'Alene Regional Office